

Chlorine Disinfection Table

Disinfectant	Year	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Violation	Likely source of contamination
Chlorine (Free)	2016	0.78	0.39	1.52	4	4	ppm	N	Water additive used to control microbes.